

## Product Information

NLS009 is a laser particle sensor that detects the dust particle concentration in air by using optical sensing method.

It is also a multi-sensor that can detect TVOC gas with a built-in gas sensor.

This multi-sensor can measure PM1.0, PM2.5, and PM10, and detect changes in the concentration of TVOC gas.



## Electrical Characteristic

characteristic	Rating
Detectable particle size	0.3 $\mu$ m ~ 20 $\mu$ m
Detectable range	0~1000 $\mu$ g/m <sup>3</sup>
Accuracy	<100 $\mu$ g/m <sup>3</sup> $\pm$ 10 $\mu$ g/m <sup>3</sup> $\geq$ 100 $\mu$ g/m <sup>3</sup> $\pm$ 10%
Resolution	1 $\mu$ g/m <sup>3</sup>
TVOC sensor accuracy	5ppm of Acetaldehyde injection, change of 50
TVOC Warm-up time	Typ. 10min
Detectable Gas	alcohol, smoke, toluene, acetone, formaldehyde and other volatile organic compounds.
Supply voltage	DC 5 $\pm$ 10%, Ripple <100mV at 60HZ
Current Consumption	< 160 mA
Signal Out put	UART Hi : > 3V, Lo : <0.7V,
Operating Temp. Range	-10~45 $^{\circ}$ C
Operating Humi. Range	95%RH or less (without dew condensation)
Storage temperature	-30~60 $^{\circ}$ C
Dimensions	49(W)x 12(T)x 35(D) mm
weight	24g

## Connector Pin Configuration

Connector : Molex 53398-0871

1. Input (5V DC/160mA)
2. Common (GND)
4. Serial port receiving Pin (RXD : TTL level 3.3V)
5. Serial port Sending Pin (TXD : TTL level 3.3V)
6. Reset Module reset (TTL level 3.3V)

## Application Ideas

- ✓ Air Purifier
- ✓ Air Quality Monitor
- ✓ Air Conditioner
- ✓ Ventilator
- ✓ Smoke type Fire alarm applicator  
by different sensor adjustments  
(customer option)

## Product Inquiry

- **Address: 717, Seongnam Central Biz Tower, 314, Galmachi-ro, Jungwon-gu, Seongnam-si, Gyeonggi-do, 13201, Gyeonggi-do**
- **Tel: 031-742-8200**
- **E-MAIL : sales@nids.co.kr**